



			Comorning	
For the following equipme	nt:			
Product Name: Din Rail Switching Power Supply				
Model Designation: HDR-30-x (x=5,12,15,24,48)				
is herewith confirmed to were applied:	comply with t	he requirements set	out in the Council I	Directive, the following standards
RoHS Directive (2011) Low Voltage Directive	, ,	•		
EN62368-1:2014+A11:2017 EN61558-1:2005+A1/EN61558-2-16:2		CB certificate No : DK-87473-UL  TUV certificate No : R50360934		
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rac	terference)	n n	U) :	Class B
Harmonic current	EN61000-			
Voltage flicker	EN61000-	3-3:2013		
EMS (Electro-Magnetic S	Susceptibility	<b>'</b> )		
EN55024:2010+A1:2015	EN61000-6-	-		
ESD air	EN61000-	4-2:2009	Level 3	8KV
ESD contact	EN61000-	4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-	4-3:2006+A1:2008+A	2:2010 Level 3	10V/m
EFT bursts	EN61000-	4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-	4-5:2014	Level 4	2KV/Line-Line
Conducted susceptibility	EN61000-	4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-	4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-	-11:2004 >95% dip 0.5	periods 30% dip 25 per	riods >95% interruptions 250 periods
Note:  A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.  The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.  For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on <a href="http://www.meanwell.com">http://www.meanwell.com</a> )" and TDF (Technical Documentation File).				
This Declaration is effective from serial number EB9xxxxxxx				
Person responsible for ma	rking this dec	claration:		
MEAN WELL Enterprises	Co., Ltd.			
(Manufacturer Name) No.28, Wuquan 3rd Rd., V	Vugu Dist., Ne	ew Taipei City 24891,	Taiwan	
(Manufacturer Address)		-0		Ma
Johnny Huang/Manager, Certification Center: (Name / Position)		(Signature)	Alex Tsai/Director, Market (Name / Position)	eting Department : (Signature)
Taiwan (Place)		Sep. 5th, 2019 (Date)		