



TREZOR TEST s.r.o.
Na Vršku 67, Klecany

CERTIFICATION BODY NO. 3025
ACCREDITED BY
THE CZECH ACCREDITATION INSTITUTE

CERTIFICATE OF CONFORMITY

Registration number: TT – 565/2015
for

SATEL Sp. z o.o.
Budowlanych 66, 80-298 Gdańsk, Poland

PRODUCT
(identification):

The control panel
type VERSA IP
chosen see Annex No. 1
Producer: SATEL Sp. z o.o.
Budowlanych 66, 80-298 Gdańsk, Poland
CZ-CPA 27.90.11

CLASSIFICATION
(of the product):

The product in accordance with the certification system 5 ISO/IEC Guide 67:2004
and in conformity with requirements of

EN 50131-1:2006, EN 50131-3:2009, EN 50136-1:2012,
EN 50131-6:2008, EN 50136-2:1998

Security Grade 2
Environmental Class II
DP4 - LAN+PSTN
SP5 (ATS-5) - LAN
SP1 (ATS-1) - PSTN

The certificate is issued on the basis of the certification report no. CE 157/2015 within the accreditation according to the certificate no. 709/2015 of 17. October 2015 issued by the Czech Accreditation Institute.

Chairman of the Certification board
CO No. 3025
Ing. Oldřich UHLÍŘ

Deputy chairman of the Certification board
CO No. 3025
Ing. Daniela ČÍŽKOVÁ

Date of issue: 17.12.2015



Date effective: 17.12.2015
Valid till: 17.12.2018

This certificate can be used and duplicated only unchanged and with all enclosures.

Certification body No. 3025
Company TREZOR TEST s.r.o.
Na Vršku 67, Klecany

Appendix 1 is an integral part of
the certificate no. TT-565/2015
Page: 1 / 1

The control panel
type VERSA IP
chosen:
VERSA-LCDM-WRL Keyboard
ACU-270 Wireless base station system
AMD-101 Wireless magnetic contact
AMD-103 Compact wireless magnetic contact
AMD-100 Wireless magnetic contact
AVD-100 Wireless vibration detector with magnetic contact
ASP-100 Wireless triggered outdoor siren
APD-100 Wireless PIR Detector
APMD-150 Wireless Dual Motion Detector
GREY Plus Digital Dual Motion Detector PIR + MW

Klecany, November 17, 2015